



Tips

Aquatics Facility Pump Room Confined Space

Are you following your confined space entry program for your pool pump pit?

These spaces may be considered permit required confined spaces because of the restricted means of entry or exit, potential hazardous atmosphere and potential serious safety hazards present.

- **Have you identified your hazards?**
 - Oxygen deficient atmosphere?
 - Hazardous gases?
 - High volume of water supply?
 - Other?
- **Do you have the right equipment?**
 - Multi-gas Monitor
 - Harness
 - Retrieval System
- **Did you complete your permit?**
- **Do you have a rescue plan?**



Multi-gas Monitor & Harness